

Отчет о потреблении тепловой энергии и теплоносителя за Январь 2021 г.

Адрес: Комсомольская 21

Тип прибора: ТСРВ-024
 Номер прибора: 802467
 Теплосистема: 1

Дата	W1, Гкал	m1, т	t1, °C	P1, МПа	W2, Гкал	m2, т	t2, °C	P2, МПа	W3, Гкал	m3, т	t3, °C	P3, МПа	W4, Гкал	m4, т	t4, °C	P4, МПа
16.12.20	10.923	152.065	71.71	0.59	8.012	151.091	52.90	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
17.12.20	9.900	152.837	64.66	0.59	7.455	151.860	48.96	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
18.12.20	10.187	153.263	66.34	0.59	7.643	152.221	50.08	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
19.12.20	10.504	152.201	68.90	0.59	7.766	151.173	51.24	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
20.12.20	11.526	151.627	75.89	0.59	8.283	150.642	54.86	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
21.12.20	11.531	151.077	76.20	0.59	8.248	150.113	54.82	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
22.12.20	11.390	151.212	75.20	0.59	8.198	150.255	54.44	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
23.12.20	10.720	152.035	70.39	0.59	7.903	151.029	52.19	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
24.12.20	10.111	151.985	66.41	0.59	7.559	150.948	49.94	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
25.12.20	10.138	152.209	66.48	0.59	7.601	151.182	50.14	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
26.12.20	10.085	152.106	66.18	0.59	7.564	151.078	49.93	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
27.12.20	9.965	152.049	65.42	0.59	7.487	151.015	49.45	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
28.12.20	9.643	152.228	63.23	0.59	7.327	151.169	48.33	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
29.12.20	9.698	152.085	63.64	0.59	7.355	151.009	48.57	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
30.12.20	10.268	152.320	67.29	0.59	7.668	151.258	50.56	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
31.12.20	10.695	152.287	70.11	0.59	7.942	151.246	52.38	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
01.01.21	10.234	152.310	67.07	0.59	7.678	151.218	50.64	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
02.01.21	10.141	152.240	66.50	0.59	7.617	151.145	50.26	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
03.01.21	10.093	152.330	66.13	0.59	7.572	151.218	49.94	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
04.01.21	9.971	152.234	65.37	0.59	7.505	151.109	49.53	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
05.01.21	9.738	152.209	63.86	0.59	7.367	151.060	48.64	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
06.01.21	9.718	151.929	63.84	0.59	7.332	150.788	48.49	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
07.01.21	10.086	151.880	66.29	0.59	7.516	150.769	49.72	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
08.01.21	10.146	152.562	66.38	0.59	7.575	151.444	49.89	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
09.01.21	10.003	152.731	65.37	0.59	7.521	151.599	49.48	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
10.01.21	9.723	153.332	63.29	0.59	7.403	152.160	48.52	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
11.01.21	10.305	153.737	66.91	0.59	7.709	152.620	50.38	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
12.01.21	11.921	153.161	77.71	0.59	8.617	152.163	56.51	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
13.01.21	11.939	153.720	77.55	0.59	8.595	152.749	56.14	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
14.01.21	11.648	157.007	74.10	0.59	8.530	156.000	54.57	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
15.01.21	10.028	157.625	63.47	0.59	7.634	156.505	48.62	0.55	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
Среднее:	10.419	152.664	68.13		7.748	151.608	50.97		0.000	0.000	0.00		0.000	0.000	0.00	
Итого:	322.976	4732.593			240.180	4699.833			0.000	0.000			0.000	0.000		

Ответственный за учет тепловой энергии: _____ / _____ /
 Отчет принят _____ 200 г. _____ / _____ /

Отчет о потреблении тепловой энергии и теплоносителя за Январь 2021 г.

Адрес: Комсомольская 21

Тип прибора: ТСРВ-024
 Номер прибора: 802467
 Теплосистема: 1

Дата	п, ч	Втс, Гкал	Втв, Гкал	Мтс, т	тхв, °С
16.12.20	24.00	2.911	0.000	0.974	0.00
17.12.20	24.00	2.445	0.000	0.977	0.00
18.12.20	24.00	2.544	0.000	1.043	0.00
19.12.20	24.00	2.737	0.000	1.028	0.00
20.12.20	24.00	3.243	0.000	0.985	0.00
21.12.20	24.00	3.283	0.000	0.964	0.00
22.12.20	24.00	3.191	0.000	0.957	0.00
23.12.20	24.00	2.818	0.000	1.006	0.00
24.12.20	24.00	2.552	0.000	1.037	0.00
25.12.20	24.00	2.537	0.000	1.027	0.00
26.12.20	24.00	2.521	0.000	1.028	0.00
27.12.20	24.00	2.478	0.000	1.034	0.00
28.12.20	24.00	2.316	0.000	1.059	0.00
29.12.20	24.00	2.343	0.000	1.076	0.00
30.12.20	24.00	2.600	0.000	1.062	0.00
31.12.20	24.00	2.753	0.000	1.041	0.00
01.01.21	24.00	2.556	0.000	1.091	0.00
02.01.21	24.00	2.525	0.000	1.095	0.00
03.01.21	24.00	2.520	0.000	1.112	0.00
04.01.21	24.00	2.466	0.000	1.125	0.00
05.01.21	24.00	2.371	0.000	1.149	0.00
06.01.21	24.00	2.386	0.000	1.141	0.00
07.01.21	24.00	2.570	0.000	1.111	0.00
08.01.21	24.00	2.571	0.000	1.119	0.00
09.01.21	24.00	2.482	0.000	1.133	0.00
10.01.21	24.00	2.320	0.000	1.172	0.00
11.01.21	24.00	2.596	0.000	1.117	0.00
12.01.21	24.00	3.305	0.000	0.999	0.00
13.01.21	24.00	3.345	0.000	0.972	0.00
14.01.21	24.00	3.118	0.000	1.007	0.00
15.01.21	24.00	2.395	0.000	1.120	0.00
Среднее:		2.671	0.000	1.057	0.000
Итого:	744.00	82.797	0.000	32.760	

Ответственный за учет тепловой энергии: _____ / _____ /
 Отчет принят _____ 200 г. _____ / _____ /