

Отчет о потреблении тепловой энергии и теплоносителя за Январь 2021 г.

Адрес: Островского д.49

Тип прибора: ТСРВ-024
 Номер прибора: 901036
 Теплосистема: 1

Дата	W1, Гкал	m1, т	t1, °C	P1, МПа	W2, Гкал	m2, т	t2, °C	P2, МПа	W3, Гкал	m3, т	t3, °C	P3, МПа	W4, Гкал	m4, т	t4, °C	P4, МПа
16.12.20	27.199	357.187	76.02	0.67	21.764	357.187	60.83	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
17.12.20	24.906	350.270	70.94	0.67	20.137	350.271	57.35	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
18.12.20	24.341	345.218	70.39	0.67	19.672	345.218	56.88	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
19.12.20	25.741	348.673	73.70	0.67	20.632	348.673	59.07	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
20.12.20	27.325	349.361	78.09	0.67	21.606	349.358	61.74	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
21.12.20	27.623	350.410	78.71	0.67	21.798	350.408	62.11	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
22.12.20	27.220	350.221	77.60	0.67	21.603	350.223	61.58	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
23.12.20	26.250	350.281	74.82	0.67	21.035	350.281	59.95	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
24.12.20	26.025	353.697	73.46	0.67	20.967	353.696	59.18	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
25.12.20	26.489	356.497	74.14	0.67	21.351	356.280	59.82	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
26.12.20	25.753	353.121	72.80	0.67	20.839	353.121	58.90	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
27.12.20	25.888	353.783	73.06	0.67	20.946	353.782	59.10	0.58	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
28.12.20	26.681	359.346	74.13	0.67	21.635	359.345	60.10	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
29.12.20	26.866	362.399	74.01	0.67	21.845	362.399	60.17	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
30.12.20	26.985	363.157	74.19	0.67	21.897	363.158	60.20	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
31.12.20	26.586	358.962	73.94	0.67	21.533	358.961	59.88	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
01.01.21	26.871	361.261	74.26	0.67	21.774	361.261	60.17	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
02.01.21	26.847	360.848	74.28	0.67	21.793	360.845	60.30	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
03.01.21	26.654	359.939	73.93	0.67	21.625	359.937	59.98	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
04.01.21	25.948	357.755	72.41	0.67	21.110	357.749	58.90	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
05.01.21	26.245	358.759	73.04	0.67	21.328	358.759	59.35	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
06.01.21	26.179	358.639	72.88	0.67	21.231	358.636	59.10	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
07.01.21	25.988	357.504	72.57	0.67	21.052	357.503	58.78	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
08.01.21	24.049	340.831	69.42	0.66	19.462	340.821	56.95	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
09.01.21	26.847	366.084	73.22	0.67	21.842	366.082	59.56	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
10.01.21	26.771	366.026	73.02	0.67	21.890	366.023	59.70	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
11.01.21	26.902	359.035	74.79	0.65	21.734	359.022	60.42	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
12.01.21	28.377	354.289	79.97	0.66	22.592	354.280	63.67	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
13.01.21	28.238	352.146	80.07	0.66	22.330	352.137	63.31	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
14.01.21	28.117	361.938	77.59	0.67	22.490	361.926	62.06	0.57	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
15.01.21	25.930	362.310	71.44	0.67	21.103	362.308	58.13	0.56	0.000	0.000	0.00	0.00	0.000	0.000	0.00	0.00
Среднее:	26.511	356.127	74.29		21.375	356.118	59.91		0.000	0.000	0.00		0.000	0.000	0.00	
Итого:	821.838	11039.945			662.616	11039.649			0.000	0.000			0.000	0.000		

Ответственный за учет тепловой энергии: _____ / _____ /

Отчет принят _____ 200 г. _____ / _____ /

Отчет о потреблении тепловой энергии и теплоносителя за Январь 2021 г.

Адрес: Островского д.49

Тип прибора: ТСРВ-024
 Номер прибора: 901036
 Теплосистема: 1

Дата	п, ч	Втс, Гкал	Втв, Гкал	Мтс, т	тхв, °С
16.12.20	24.00	5.435	0.000	0.000	0.00
17.12.20	24.00	4.768	0.000	-0.004	0.00
18.12.20	24.00	4.668	0.000	0.000	0.00
19.12.20	24.00	5.109	0.000	0.000	0.00
20.12.20	24.00	5.719	0.000	0.002	0.00
21.12.20	24.00	5.826	0.000	0.002	0.00
22.12.20	24.00	5.616	0.000	-0.002	0.00
23.12.20	24.00	5.216	0.000	0.000	0.00
24.12.20	24.00	5.058	0.000	0.000	0.00
25.12.20	24.00	5.138	0.000	0.218	0.00
26.12.20	24.00	4.914	0.000	-0.001	0.00
27.12.20	24.00	4.942	0.000	0.001	0.00
28.12.20	24.00	5.047	0.000	0.000	0.00
29.12.20	24.00	5.021	0.000	-0.002	0.00
30.12.20	24.00	5.087	0.000	-0.003	0.00
31.12.20	24.00	5.053	0.000	0.000	0.00
01.01.21	24.00	5.096	0.000	0.001	0.00
02.01.21	24.00	5.055	0.000	0.003	0.00
03.01.21	24.00	5.029	0.000	0.002	0.00
04.01.21	24.00	4.838	0.000	0.006	0.00
05.01.21	24.00	4.917	0.000	0.000	0.00
06.01.21	24.00	4.947	0.000	0.003	0.00
07.01.21	24.00	4.936	0.000	0.000	0.00
08.01.21	24.00	4.587	0.000	0.010	0.00
09.01.21	24.00	5.005	0.000	0.002	0.00
10.01.21	24.00	4.882	0.000	0.003	0.00
11.01.21	24.00	5.168	0.000	0.014	0.00
12.01.21	24.00	5.785	0.000	0.009	0.00
13.01.21	24.00	5.907	0.000	0.008	0.00
14.01.21	24.00	5.627	0.000	0.012	0.00
15.01.21	24.00	4.827	0.000	0.002	0.00
Среднее:		5.136	0.000	0.009	0.000
Итого:	744.00	159.222	0.000	0.287	

Ответственный за учет тепловой энергии: _____ / _____ /

Отчет принят _____ 200 г. _____ / _____ /